



CERTIFICATE OF APPROVAL

No. CF 118

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

DORMA UK LIMITED

Wilbury Way, Hitchin, Hertfordshire SG4 0AB

Tel: 01462 477600

Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**Dorma TS 83 Overhead
Mounted Door Closer**

TECHNICAL SCHEDULE

**TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories
To Fire Resisting Doorsets**

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight
Chairman - Management Council

Issued: 3rd February 1992
Reissued: 18th February 2012
Valid to: 17th February 2017

Page 1 of 4



Seal is in place Only valid when authentic CERTIFIRE



CERTIFICATE No CF 118

DORMA UK LTD

DORMA TS83 OVERHEAD MOUNTED DOOR CLOSER

1. Dorma TS 83 is an overhead mounted door closing device with adjustable power and integral backcheck and delayed action functions. The variants covered by this approval are the TS83BCDC EN2-5, TS83BCDC EN3-6, TS83BC EN2-5, TS83BC EN3-6 and TS83BC EN7.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. This approval relates to its use with the following door assemblies:-
 - Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).**
 - Latched and unlatched door assemblies (intumescent sealed or non-intumescent sealed) consisting of uninsulated or insulated metal door assemblies in metal frames, having a fire resistance of up to 240 minutes (IMM and MM).**
 - Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in steel frames having a fire resistance up to 120 minutes (Code ITM).**
4. The closers are approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1
 - ii) An appraisal against TS34
 - iii) Certification of quality management system to ISO 9001: 2000.
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
5. This approval is applicable only to the specified closers used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
6. The approval relates to on going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.



CERTIFICATE No CF 118 DORMA UK LTD

DORMA TS83 OVERHEAD MOUNTED DOOR CLOSER

7. The following tables show acceptable doorsets types and fire resistance periods:

For doorsets to BS 476: Part 22: 1987

Fire resistance performance as	MM	IMM	TT	ITT	ITM	ITC
FD20	✓	✓	x	✓	✓	x
FD30	✓	✓	x	✓	✓	x
FD60	✓	✓	x	✓	✓	x
FD90	✓	✓	x	✓	✓	x
FD120	✓	✓	x	✓	✓	x
FD240	✓	✓	x	x	x	x

For doorsets to EN 1634-1

Classification to EN13501-2	MM	IMM	TT	ITT	ITM	ITC
E 20	✓	✓	x	✓	✓	x
EI 20	✓	✓	x	✓	✓	x
E 30	✓	✓	x	✓	✓	x
EI 30	✓	✓	x	✓	✓	x
E60	✓	✓	x	✓	✓	x
EI 60	✓	✓	x	✓	✓	x
E 90	✓	✓	x	✓	✓	x
EI 90	✓	✓	x	✓	✓	x
E 120	✓	✓	x	✓	✓	x
EI120	✓	✓	x	✓	✓	x
E240	✓	✓	x	x	x	x
EI240	✓	✓	x	x	x	x

See CERTIFIRE Technical Schedules for designation of doorset types i.e. IMM etc.

Scope of Approval:

Doors may not include uninsulated glass above 20% of their total area.

The closer may not be fitted to doorsets incorporating timber leaves without leaf/frame edge intumescent protection.



CERTIFICATE No CF 118
DORMA UK LTD

DORMA TS83 OVERHEAD MOUNTED DOOR CLOSER

Classification codes

The above approval provides the following classification:

TS83BC EN7 when mounted in projecting arm (Figure 1) and transom mount (Figure 61)

4	8	7	1	1	4
---	---	---	---	---	---

TS83BCDC EN3-6 and TS83BC EN3-6 when mounted in projecting arm (Figure 1) and transom mount (Figure 61)

4	8	6 3	1	1	4
---	---	--------	---	---	---

TS83BCDC EN2-5 and TS83BC EN2-5 when mounted in projecting arm (Figure 1) and transom mount (Figure 61)

4	8	5 3	1	1	4
---	---	--------	---	---	---

TS83BCDC EN2-5 and TS83BC EN2-5 when mounted in parallel arm (Figure 6).

4	8	3 4	1	1	4
---	---	--------	---	---	---

TS83BCDC EN3-6 and TS83BC EN3-6 when mounted in parallel arm (Figure 6).

4	8	3 5	1	1	4
---	---	--------	---	---	---

Further Information

Further information regarding the details contained in this data sheet may be obtained from Dorma UK Limited (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).